

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-1157:0104

Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Digital Monitoring Products 2500 N. Partnership Blvd, Springfield, MO 65803  
Contact: Terry Shelton (417) 831-9362 Fax (417) 831-1325  
Email: tshelton@dmp.com

**DESIGN:** Model XR5FC and XR5SL fire alarm control units. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Model XR5SL does not employ a bell output circuit or 4-wire detector power, it is used for slave applications deriving its power from the host (master) control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

XR5FC, XR5SL; Control Panels  
630F\*, 692F; Keypad  
865, 866; Bell Module  
320; Power Transformer  
377; Trouble Indicator Module  
\*714, \*715; Zone Expanders

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

The control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for details.

This control unit meets the requirements of UL Standard 864, 9th Edition.

**NOTE:** For Alarm Verification Feature, the maximum Retard/Reset/Restart (including smoke detector reset time) shall not exceed 30 seconds.

\*Rev. 02-19-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*